Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 170

Customer

Facility Name: *Homewood Suites By Hilton*

Address: *1410 Smallman St*
Piitsburgh,PA 15222

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/23/26*
Time: 11:02 AM
Method: *Grab*

Sample Final Analysis

Date: *9/26/26*
Time: *10:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/26	10:00 AM	AH	SM 9222B
Standard plate count:	50/ml	200/ml	9/23/26	4:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	9/23/26	11:02 AM	SL	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	9/23/26	11:02 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/23/26	11:02 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor