

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 184

Customer

Facility Name: *Imperial House*

Address: *5600 Munhall Rd.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *Collection*
Time: 12:00 AM
Method: *Grab*

Sample Final Analysis

Date: *1/0/00*
Time: *12:00 AM*
Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Final Report	Absent	Fecal Colifo	12:00 AM	0	SM 9222G
Total coliforms:	0/100mls	2/100mls	Total Colifor	12:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	HPC Incuba	12:00 AM	0	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	Fecal Strept	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	0.0 SU	7.2 - 7.8 SU	Collection	12:00 AM	0	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	Collection	12:00 AM	0	DPD
Turbidity:	0 NTU	1 - 2 NTU	Collection	12:00 AM	0	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor