# Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

*Lab# 2287*

***Customer***

*Facility Name:* *Ingomar North Swim Club*

*Address:* *460 Olive Street*
*Pittsburgh, PA 15237*

*Matrix:* *Recreational Water*

*Source Type:* *Baby Pool*

***Sample Collection***

*Date:* *8/27/26*
*Time:* 2:05 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *8/29/26*
*Time:* *5:00 PM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/27/26 | 4:40 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/27/26 | 4:40 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/27/26 | 4:30 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/27/26 | 2:05 PM | EG | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/27/26 | 2:05 PM | EG | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/27/26 | 2:05 PM | EG | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)