Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 451

Customer

Facility Name: *Kiski Area H.S.*

Address: *240 Hyde Park Rd.*
Leechburg, PA 15656

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/29/26*
Time: 9:55 AM
Method: *Grab*

Sample Final Analysis

Date: *10/2/26*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/30/26	9:25 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/30/26	9:25 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/29/26	5:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/29/26	9:55 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/29/26	9:55 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/29/26	9:55 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor