# Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
**Laboratory Analysis Report**

**Lab ID No. 02-04041**

**E-1**

***Lab# 192***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *John H. Linton* | *Date:* | *10/13/26* |
| | | *Time:* | 1:05 PM |
| *Address:* | *250 Aster St.* | *Method:* | *Grab* |
| | *Pittsburgh, PA 15235* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *10/16/26* |
| | | *Time:* | *10:00 AM* |
| *Source Type:* | *Small Pool* | *Analyst:* | *JC* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 10/14/26 | 9:55 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/14/26 | 9:55 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/13/26 | 2:56 PM | MH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 10/13/26 | 1:05 PM | SH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 10/13/26 | 1:05 PM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/13/26 | 1:05 PM | SH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)