Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 220

Customer

Facility Name: *Masonic Village*

Address: *1000 Masonic Dr.*
Sewickley, PA 15143

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *10/13/26*
Time: 12:38 PM
Method: *Grab*

Sample Final Analysis

Date: *10/16/26*
Time: *11:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/14/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/13/26	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/13/26	12:38 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/13/26	12:38 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/13/26	12:38 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor