Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2376

Customer

Facility Name: *Oakmont C.C.*

Address: *1233 Hulton Road*
Oakmont, PA 15139

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *8/24/26*
Time: 12:42 PM
Method: *Grab*

Sample Final Analysis

Date: *8/27/26*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/25/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/25/26	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/24/26	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/24/26	12:42 PM	BG	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/24/26	12:42 PM	BG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/24/26	12:42 PM	BG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor