B & R Pools and Swim Shop

Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Service

Lab#* *380

Customer		***Sample Collection***	
Facility Name:	*PPG Paints Arena*	*Date:*	*10/13/26*
		Time:	12:30 PM
Address:	*1001 Fifth Ave* *Pittsburgh, PA 15219*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/16/26*
		Time:	*10:00 AM*
Source Type:	*Therapy Spa*	*Analyst:*	*JC*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	10/14/26	9:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	9:55 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/13/26	5:34 PM	MH	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	10/14/26	10:20 AM	MH	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.4 SU	7.2 - 7.8 SU	10/13/26	12:30 PM	MB	DPD
Chlorine:	2.2 mg/l	1.0 - 5.0 mg/l	10/13/26	12:30 PM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/13/26	12:30 PM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor