**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**

**Laboratory Analysis Report**

**Lab ID No. 02-04041**

**C-10**

***Lab# 2402***

***Customer***

*Facility Name:* *Pgh Golf Club*

*Address:* *5280 Northumberland St. Pittsburgh, PA 15217*

*Matrix:* *Recreational Water*

*Source Type:* *Pool- Shallow*

***Sample Collection***

*Date:* *8/25/26*
*Time:* 2:53 PM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *8/28/26*
*Time:* *10:30 AM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/26/26 | 10:00 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/26/26 | 10:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/25/26 | 4:55 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/25/26 | 2:53 PM | JT | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 8/25/26 | 2:53 PM | JT | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/25/26 | 2:53 PM | JT | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor