Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Service

Lab ID No. 02-04041

Lab# ***2516***

Laboratory Analysis Report

Customer

Facility Name: *Summerset at Frick Park*

Address: *1425 Parkview Blvd.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Wading Pool*

Sample Collection

Date: *10/12/26*
Time: 11:00 AM
Method: *Grab*

Sample Final Analysis

Date: *10/15/26*
Time: *10:00 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/13/26	9:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/13/26	9:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/12/26	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/12/26	11:00 AM	JR	DPD
Chlorine:	1.6 mg/l	1.0 - 5.0 mg/l	10/12/26	11:00 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/12/26	11:00 AM	JR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor