# Dream Pools and Spas
# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**C-1**

***Lab# 261***

***Customer***

*Facility Name:* *Rehabilitation Institute*

*Address:* *1405 Shady Ave.*
*Pittsburgh, PA 15217*

*Matrix:* *Recreational Water*

*Source Type:* *Pool - Lg*

***Sample Collection***

*Date:* *9/29/26*
*Time:* 8:52 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *10/2/26*
*Time:* *9:00 AM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 9/30/26 | 8:55 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/30/26 | 8:55 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/29/26 | 4:30 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 9/29/26 | 8:52 AM | JT | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 9/29/26 | 8:52 AM | JT | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/29/26 | 8:52 AM | JT | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor