Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 266

Customer

Facility Name: *Residence Inn*

Address: *574 W. General Robinson St. Pittsburgh, PA 15212*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/24/26*

Time: 9:35 AM

Method: *Grab*

Sample Final Analysis

Date: *8/28/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/25/26	10:45 AM	AS	SM 9222G
Total coliforms:	10/100mls	2/100mls	8/25/26	10:45 AM	AS	SM 9222B
Standard plate count:	570/ml	200/ml	8/24/26	5:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/24/26	9:35 AM	MB	DPD
Chlorine:	0.2 mg/l	1.0 - 5.0 mg/l	8/24/26	9:35 AM	MB	DPD
Turbidity:	2 NTU	1 - 2 NTU	8/24/26	9:35 AM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor