Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Extra

Lab# ***2479***

Customer			***Sample Collection***	
Facility Name:	*Seven Springs Resort*		*Date:*	*10/12/26*
			Time:	9:42 AM
Address:	*777 Waterwheel Dr.*	*Seven Springs*	*Method:*	*Grab*
	Champion, PA 15622			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*10/15/26*
			Time:	*10:00 AM*
Source Type:	*Barvarian Beach Pool*		*Analyst:*	*JC*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/13/26	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/13/26	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/12/26	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	10/12/26	9:42 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	10/12/26	9:42 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/12/26	9:42 AM	JC	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)