Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 277

Customer		***Sample Collection***	
Facility Name:	*Shaler Area Elementary School*	*Date:*	*9/30/26*
		Time:	7:30 AM
Address:	*700 Scott Ave.*	*Method:*	*Grab*
	Glenshaw, PA 15116		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/3/26*
		Time:	*10:30 AM*
Source Type:	*Pool Deep*	*Analyst:*	*JC*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	10/1/26	10:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/26	10:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/30/26	4:45 PM	MH	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.4 SU	7.2 - 7.8 SU	9/30/26	7:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/30/26	7:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/30/26	7:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor