Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 504

Customer

Facility Name: *University of Pgh Recreation*

Address: *3719 Terrace St.*
Pittsburgh, PA 15213

Matrix: *University of Pgh Recreation*

Source Type: *Spa*

Sample Collection

Date: *9/1/26*
Time: 11:32 AM
Method: *Grab*

Sample Final Analysis

Date: *9/4/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/2/26	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/2/26	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/1/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/1/26	11:32 AM	JT	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/1/26	11:32 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/1/26	11:32 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor