# Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

*Lab# 303*

***Customer***

*Facility Name:* *University of Pittsburgh*

*Address:* *3501 Allequippa St. Pittsburgh, PA 15260*

*Matrix:* *Recreational Water*

*Source Type:* *Lg Pool Middle 1*

***Sample Collection***

*Date:* *9/15/26*

*Time:* 12:35 PM

*Method:* *Grab*

***Sample Final Analysis***

*Date:* *9/18/26*

*Time:* *9:00 AM*

*Analyst:* *JC*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 9/16/26 | 8:55 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/16/26 | 8:55 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/15/26 | 3:40 PM | MH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 9/15/26 | 12:35 PM | JT | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 9/15/26 | 12:35 PM | JT | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/15/26 | 12:35 PM | JT | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor