Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 303

Customer

Facility Name: *University of Pittsburgh*

Address: *3501 Allequippa St. Pittsburgh, PA 15260*

Matrix: *Recreational Water*

Source Type: *Lg Pool Middle 1*

Sample Collection

Date: *10/14/26*

Time: 1:42 PM

Method: *Grab*

Sample Final Analysis

Date: *10/16/26*

Time: *5:30 PM*

Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/14/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	5:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	10/14/26	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/14/26	1:42 PM	SL	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	10/14/26	1:42 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/14/26	1:42 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor