# Dream Pools and Spas
# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

**Lab ID No. 02-04041**

**S-1**

***Lab# 319***

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Upper St. Clair Rec.* | *Date:* | *10/12/26* |
| | | *Time:* | 2:34 PM |
| *Address:* | *1551 Mayview Road* | *Method:* | *Grab* |
| | *Upper St. Clair, PA 15241* | | |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *10/15/26* |
| | | *Time:* | *10:30 AM* |
| *Source Type:* | *Lap Pool Shallow* | *Analyst:* | *JC* |

| **Accredited Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 10/13/26 | 10:10 AM | MH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/13/26 | 10:10 AM | MH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/12/26 | 5:10 PM | AS | SM 9215B |

| **Field Analysis** | **Results** | **Reporting limit** | **Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 10/12/26 | 2:34 PM | MM | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 10/12/26 | 2:34 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/12/26 | 2:34 PM | MM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor