Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 492

Customer		***Sample Collection***	
Facility Name:	*Wildwood British Swim School*	*Date:*	*9/14/26*
		Time:	2:39 PM
Address:	*2344 Wildwood Rd.* *Gibsonia,PA 15044*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*9/17/26*
		Time:	*11:00 AM*
Source Type:	*Pool*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	10:45 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	10:45 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26	5:27 PM	JC	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	9/14/26	2:39 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/14/26	2:39 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	2:39 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)