Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2583

Customer

Facility Name: *Wildwood Golf Club*

Address: *2195 Sample Road*
Allison Park, PA 15101

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *8/25/26*
Time: 11:28 AM
Method: *Grab*

Sample Final Analysis

Date: *8/28/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/26	11:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/26	11:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/26	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/25/26	11:28 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/25/26	11:28 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/26	11:28 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor