Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-2

Lab# 119

Customer

Facility Name: *Wingate*

Address: *210 Executive Dr.*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/21/26*
Time: 3:39 PM
Method: *Grab*

Sample Final Analysis

Date: *9/24/26*
Time: *9:30 AM*
Analyst: *#REF!*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/22/26	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/22/26	9:20 AM	AH	SM 9222B
Standard plate count:	100/ml	200/ml	9/21/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	9/21/26	3:39 PM	SL	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	9/21/26	3:39 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/21/26	3:39 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor