**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**

# Laboratory Analysis Report

**Lab ID No. 02-04041**

**N-12**

***Lab# 2025***

***Customer***

*Facility Name:* *Bairel Center*

*Address:* *2565 Nicholson Road*
*Sewickley, PA 15143*

*Matrix:* *Recreational Water*

*Source Type:* *Pool*

***Sample Collection***

*Date:* *8/27/26*
*Time:* 10:20 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *8/29/26*
*Time:* *5:00 PM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/27/26 | 4:40 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/27/26 | 4:40 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/27/26 | 4:30 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/27/26 | 10:20 AM | SL | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 8/27/26 | 10:20 AM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/27/26 | 10:20 AM | SL | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)