

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 2635

Customer

Facility Name: *Village Cranberry Woods Apt.*

Address: *5001 Pendleton Way*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *9/14/26*
Time: 1:55 PM
Method: *Grab*

Sample Final Analysis

Date: *9/17/26*
Time: *11:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/15/26	11:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/15/26	11:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/14/26	5:37 PM	JC	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/14/26	1:55 PM	MM	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	9/14/26	1:55 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/14/26	1:55 PM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)