Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

APM

Lab# ***406***

Customer		***Sample Collection***	
Facility Name:	*Morrow Park*	*Date:*	*10/14/26*
		Time:	10:15 AM
Address:	*5250 Liberty Ave*	*Method:*	*Grab*
	Pittsburgh, PA 15224		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/16/26*
		Time:	*5:30 PM*
Source Type:	*Pool*	*Analyst:*	*JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/14/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	5:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	10/14/26	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	10/14/26	10:15 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/14/26	10:15 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/14/26	10:15 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor