Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# *2183*

Customer

Facility Name: *Fairways of Oakmont*

Address: *Fairways Drive*
Oakmont, PA 15139

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/31/26*
Time: 11:06 AM
Method: *Grab*

Sample Final Analysis

Date: *9/3/26*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/1/26	8:55 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/1/26	8:55 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/31/26	3:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/31/26	11:06 AM	BG	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	8/31/26	11:06 AM	BG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/31/26	11:06 AM	BG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor