Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Pace

Lab# 510

Customer

Facility Name: *Pace Analytical*

Address: *1803 Philadelphia St.*
Indiana, PA 15701

Matrix: *Recreational Water*

Source Type: *Hot 1*

Sample Collection

Date: *10/14/26*
Time: 11:24 AM
Method: *Grab*

Sample Final Analysis

Date: *10/16/26*
Time: *5:30 PM*
Analyst: *JC*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/14/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	5:00 PM	AS	SM 9222B
Standard plate count:	200/ml	200/ml	10/14/26	4:15 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/14/26	4:30 PM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	6.5 SU	7.2 - 7.8 SU	10/14/26	11:24 AM	TS	DPD
Chlorine:	N/A	1.0 - 5.0 mg/l	10/14/26	11:24 AM	TS	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/14/26	11:24 AM	TS	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)