Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Pace

Lab# 513

Customer		***Sample Collection***	
Facility Name:	*Pace Analytical*	*Date:*	*10/14/26*
		Time:	11:12 AM
Address:	*1803 Philadelphia St.* *Indiana, PA 15701*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/16/26*
		Time:	*5:30 PM*
Source Type:	*Hot 2*	*Analyst:*	*JC*

Laboratory Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	10/14/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/26	5:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	10/14/26	4:15 PM	AS	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	10/14/26	4:30 PM	AS	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	6.4 SU	7.2 - 7.8 SU	10/14/26	11:12 AM	TS	DPD
Chlorine:	N/A	1.0 - 5.0 mg/l	10/14/26	11:12 AM	TS	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/14/26	11:12 AM	TS	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)