Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 213

Customer

Facility Name: *Langley High School*

Address: *2940 Sheradan Blvd.*
Pittsburgh, PA 15204

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *10/14/26*
Time: 7:53 AM
Method: *Grab*

Sample Final Analysis

Date: *10/16/26*
Time: *5:30 PM*
Analyst: *JC*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/14/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	A	10/14/26	5:00 PM	AS	SM 9222B
Standard plate count:	0/ml	A	10/14/26	4:15 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	10/14/26	7:53 AM	MM	DPD
Chlorine:	2.0 mg/l	B	10/14/26	7:53 AM	MM	DPD
Turbidity:	1 NTU	A	10/14/26	7:53 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)