



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2805

Customer

Facility Name: Apex Newbury
Address: 2200 Alpha Dr.
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/23/26
Time: 2:30 PM
Method: Grab

Sample Final Analysis

Date: 6/26/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	10:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	10:30 AM	MD	SM 9222B
Standard plate count:	50/ml	200/ml	6/23/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/26	2:30 PM	JB	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	6/23/26	2:30 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	2:30 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor