



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2120

Customer

Facility Name: Club at Nevillewood
Address: 1000 Nevillewood Drive
Presto, PA 15142

Matrix: Recreational Water

Source Type: Small Pool

Sample Collection

Date: 6/23/26
Time: 3:30 PM
Method: Grab

Sample Final Analysis

Date: 6/26/26
Time: 5:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	5:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	5:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/23/26	3:30 PM	JB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/26	3:30 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	3:30 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor