



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 133

Customer

Facility Name: Hampton Inn Uniontown

Address: 698 West Main Street
Uniontown, Pa 15401

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 6/8/26

Time: 1:15 PM

Method: Grab

Sample Final Analysis

Date: 6/10/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/9/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/9/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/8/26	5:40 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/9/26	12:00 PM	MD	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/8/26	1:15 PM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/8/26	1:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/8/26	1:15 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)