



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2277

Customer

Facility Name: *Hunting Ridge*
Address: *401 Meeting House Rd.*
Bridgeville, PA 15017

Sample Collection

Date: *6/8/26*
Time: *11:25 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *6/10/26*
Time: *10:30 AM*
Analyst: *AS*

Source Type: *Deep End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/9/26	10:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/9/26	10:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/8/26	4:09 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/8/26	11:25 AM	JB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/8/26	11:25 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/8/26	11:25 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor