



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 497

Customer

Facility Name: Sure Stay
Address: 1924 Leesburg Grove City Road
Grove City, PA, 16127

Sample Collection

Date: 6/9/26
Time: 9:40 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/11/26
Time: 12:30 PM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/9/26	9:40 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/9/26	9:40 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/26	9:40 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)