



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2752

Customer

Facility Name: Scott Twp.
Address: 301 Lindsay Road
Carnegie, PA 15106

Matrix: Recreational Water

Source Type: Splash Pad

Sample Collection

Date: 6/8/26
Time: 11:41 AM
Method: Grab

Sample Final Analysis

Date: 6/10/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/9/26	11:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/9/26	11:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/8/26	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/8/26	11:41 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/8/26	11:41 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/8/26	11:41 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)