



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2562

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Waterford at Nevillewood*

Address: *1900 Tee Court*
Presto, PA 15142

Sample Collection

Date: *6/8/26*
Time: *2:15 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *6/10/26*
Time: *12:30 PM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/9/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/9/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/8/26	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/8/26	2:15 PM	JB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/8/26	2:15 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/8/26	2:15 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor