



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2607

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Yards @ 3 Crossings*

Address: *2645 Railroad St.*
Pittsburgh, PA 15222

Sample Collection

Date: *6/8/26*

Time: *9:22 AM*

Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *6/10/26*

Time: *12:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	6/9/26	12:00 PM	MD	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	6/9/26	12:00 PM	MD	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	20/ml	200/ml	6/8/26	7:05 PM	SL	SM 9215B
-----------------------	-------	--------	--------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

pH:	7.0 SU	7.2 - 7.8 SU	6/8/26	9:22 AM	JMH	DPD
-----	--------	--------------	--------	---------	-----	-----

Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	6/8/26	9:22 AM	JMH	DPD
-----------	----------	----------------	--------	---------	-----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/8/26	9:22 AM	JMH	Visual
------------	-------	-----------	--------	---------	-----	--------

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor