



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2189

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Forest Glen

Date: 6/9/26

Address: 1514 Forest Green Dr.
Moon, PA 15108

Time: 12:00 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/11/26

Time: 10:30 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/26	10:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/26	10:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/26	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/9/26	12:00 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/26	12:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/26	12:00 PM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)