



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 3**

Lab# 2280

**Customer**      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*      *Hyland Hills*  
*Address:*            *275 Oakville Dr.*  
                              *Pittsburgh, PA 15220*

**Sample Collection**

*Date:*                  6/8/26  
*Time:*                12:00 AM  
*Method:*            Grab

*Matrix:*              *Recreational Water*  
*Source Type:*      *Deep End*

**Sample Final Analysis**

*Date:*                  6/10/26  
*Time:*                11:30 AM  
*Analyst:*             AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/9/26               | 11:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/9/26               | 11:00 AM | AH      | SM 9222B |
| Standard plate count: | 50/ml    | 200/ml          | 6/8/26               | 6:05 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/8/26    | 8:04 AM | SL      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 6/8/26    | 8:04 AM | SL      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/8/26    | 8:04 AM | SL      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor