



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2327**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Longvue C.C.*

*Address:*      *400 Longue Vue Dr.*  
*Verona, PA 15147*

*Matrix:*      *400 Longue Vue Dr.*

*Source Type:*      *Shallow End*

**Sample Collection**

*Date:*      *6/8/26*  
*Time:*      *6:10 PM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Date:*      *6/10/26*  
*Time:*      *12:30 PM*  
*Analyst:*      *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 6/9/26                      | 12:00 PM | AH             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 6/9/26                      | 12:00 PM | AH             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 6/8/26                      | 7:05 PM  | SL             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|---------|----------------|---------------|
| pH:                   | 7.4 SU         | 7.2 - 7.8 SU           | 6/8/26           | 6:10 PM | DW             | DPD           |
| Chlorine:             | 1.0 mg/l       | 1.0 - 5.0 mg/l         | 6/8/26           | 6:10 PM | DW             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 6/8/26           | 6:10 PM | DW             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor