



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 046

Customer

Facility Name: Carrick High School
Address: 125 Parkfield St.
Pittsburgh, PA 15210

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 6/8/26
Time: 9:55 AM
Method: Grab

Sample Final Analysis

Date: 6/10/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	6/9/26	10:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	A	6/9/26	10:00 AM	MD	SM 9222B
Standard plate count:	0/ml	A	6/8/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	6/8/26	9:55 AM	JT	DPD
Chlorine:	4.0 mg/l	B	6/8/26	9:55 AM	JT	DPD
Turbidity:	1 NTU	A	6/8/26	9:55 AM	JT	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)