Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 497

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Park Inn*	*Date:*	*7/7/25*
		Time:	3:30 PM
Address:	*1924 Leesburg Grove City Road*	*Method:*	*Grab*
	Grove City, PA,16127		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/10/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/7/25	3:30 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/7/25	3:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	3:30 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 497

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Park Inn*	*Date:*	*7/7/25*
		Time:	3:30 PM
Address:	*1924 Leesburg Grove City Road*	*Method:*	*Grab*
	Grove City, PA,16127		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/10/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/7/25	3:30 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/7/25	3:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	3:30 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor