Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 503

[redacted]

Customer		***Sample Collection***	
Facility Name:	*University of Pgh Rec and Wellness*	*Date:*	*10/8/25*
		Time:	10:30 AM
Address:	*3719 Terrace St,*	*Method:*	*Grab*
	Pittsburgh, PA 15213		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*10/10/25*
		Time:	*5:30 PM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/8/25	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/8/25	3:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/8/25	10:30 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/8/25	10:30 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/8/25	10:30 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor