Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 504

Customer

Facility Name: *University of Pgh Rec and Wellness*

Address: *3719 Terrace St, Pittsburgh, PA 15213*

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *9/30/25*
Time: 10:49 AM
Method: *Grab*

Sample Final Analysis

Date: *10/3/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/1/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/30/25	3:10 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/1/25	11:30 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/30/25	10:49 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/30/25	10:49 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/30/25	10:49 AM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor