



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 476

Customer

Facility Name: Comfort Suites
Address: 140 Stroehman Dr.
Altoona, PA 16601
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 10/6/26
Time: 3:00 PM
Method: Grab

Sample Final Analysis

Date: 10/9/26
Time: 9:30 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/26	9:20 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/26	9:20 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/6/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	10/6/26	3:00 PM	DNP	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	10/6/26	3:00 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/26	3:00 PM	DNP	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)