



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 064

Customer

Facility Name: *Comfort Inn - RIDC*

Address: *180 Gamma Dr.
Pittsburgh, PA 15238*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *10/6/26*

Time: *9:29 AM*

Method: *Grab*

Sample Final Analysis

Date: *10/9/26*

Time: *9:00 AM*

Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/26	8:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/26	8:55 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/6/26	4:14 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	10/6/26	9:29 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/6/26	9:29 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/26	9:29 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)