



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-2

Lab# 168

Customer

Facility Name: Home 2 Suites

Address: 8630 Duncan Ave.
Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/6/26

Time: 12:12 PM

Method: Grab

Sample Final Analysis

Date: 10/10/26

Time: 10:30 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/26	10:00 AM	JC	SM 9222G
Total coliforms:	200/100mls	2/100mls	10/7/26	10:00 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	10/6/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	10/6/26	12:12 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/6/26	12:12 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/26	12:12 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor