



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 175

Customer

Facility Name: Hyatt House

Address: 2795 South Water St.
Pittsburgh, PA 15603

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/5/26

Time: 2:42 PM

Method: Grab

Sample Final Analysis

Date: 10/8/26

Time: 10:00 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/6/26	9:55 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/6/26	9:55 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/5/26	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/5/26	2:42 PM	SL	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	10/5/26	2:42 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/5/26	2:42 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)