



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 185

Customer

Facility Name: Jewish Community Center

Address: 345 Kane Blvd.
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 10/6/26

Time: 3:07 PM

Method: Grab

Sample Final Analysis

Date: 10/9/26

Time: 9:30 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/26	9:20 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/26	9:20 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/6/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/6/26	3:07 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/6/26	3:07 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/26	3:07 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)