



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 224

Customer

Facility Name: *McKeesport High School*

Address: *1960 Eden Park Blvd.
McKeesport, PA 15132*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *10/5/26*

Time: *2:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *10/8/26*

Time: *10:00 AM*

Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/6/26	9:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/6/26	9:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/5/26	4:05 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	10/5/26	2:15 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/5/26	2:15 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/5/26	2:15 PM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)