



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 254

Customer

Facility Name: *Peters Twp. High School*

Address: *121 Rolling Hills Dr.*
McMurray, PA 15317

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *10/7/26*

Time: *9:20 AM*

Method: *Grab*

Sample Final Analysis

Date: *10/9/26*

Time: *5:00 PM*

Analyst: *JC*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/26	4:45 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/26	4:45 PM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	10/7/26	4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/7/26	9:20 AM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/7/26	9:20 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/7/26	9:20 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)